



**AALBORG UNIVERSITY**  
DENMARK

**Aalborg Universitet**

## **A Simple Autonomous Current-Sharing Control Strategy for Fast Dynamic Response of Parallel Inverters in Islanded Microgrids**

Guan, Yajuan; Quintero, Juan Carlos Vasquez; Guerrero, Josep M.

*Published in:*

Proceedings of the 2014 IEEE International Energy Conference (ENERGYCON)

*DOI (link to publication from Publisher):*

[10.1109/ENERGYCON.2014.6850426](https://doi.org/10.1109/ENERGYCON.2014.6850426)

*Publication date:*

2014

*Document Version*

Early version, also known as pre-print

[Link to publication from Aalborg University](#)

*Citation for published version (APA):*

Guan, Y., Vasquez, J. C., & Guerrero, J. M. (2014). A Simple Autonomous Current-Sharing Control Strategy for Fast Dynamic Response of Parallel Inverters in Islanded Microgrids. In Proceedings of the 2014 IEEE International Energy Conference (ENERGYCON). (pp. 182-188 ). IEEE Press. (I E E E International Energy Conference. ENERGYCON proceedings). DOI: 10.1109/ENERGYCON.2014.6850426

### **General rights**

Copyright and moral rights for the publications made accessible in the public portal are retained by the authors and/or other copyright owners and it is a condition of accessing publications that users recognise and abide by the legal requirements associated with these rights.

- ? Users may download and print one copy of any publication from the public portal for the purpose of private study or research.
- ? You may not further distribute the material or use it for any profit-making activity or commercial gain
- ? You may freely distribute the URL identifying the publication in the public portal ?

### **Take down policy**

If you believe that this document breaches copyright please contact us at [vbn@aub.aau.dk](mailto:vbn@aub.aau.dk) providing details, and we will remove access to the work immediately and investigate your claim.

# A Simple Autonomous Current-Sharing Control Strategy for Fast Dynamic Response of Parallel Inverters in Islanded Microgrids

Yajuan Guan<sup>\*\*</sup>, Juan C. Vasquez<sup>#</sup>, and Josep M. Guerrero<sup>#</sup>

<sup>#</sup> Institute of Energy Technology, Aalborg University, Denmark Microgrids Research Programme [www.microgrids.et.aau.dk](http://www.microgrids.et.aau.dk)

<sup>\*\*</sup> Institute of Electrical Engineering, Chinese Academy of Sciences, Beijing, China

{ygu, juq, joz}@et.aau.dk

**Abstract**—This paper proposed a novel control strategy based on a virtual resistance and a phase locked loop for parallel three-phase inverters. The proposed controller can overcome the drawbacks of the conventional droop control such as slow transient response, complex design, and limited stability margins. The load sharing capability can be also obtained under asymmetrical output impedances in which the conventional droop controller was not properly working. The proposed approach has been verified by means of simulations and experimental results in a laboratory-scale prototype.

**Keywords:** Parallel inverters, droop control, phase-locked loop, virtual resistance.

## I. INTRODUCTION

**D**roop control method emulates the behavior of a synchronous generators by measuring active and adjusting frequency accordingly. In a similar way, reactive power can also be controlled by adjusting voltage amplitude [1]. These droop schemes are often named  $P$ - $f$  and  $Q$ - $V$  droops [2]. They have been usually preferred for the autonomous control of parallel inverters in the last decade in islanded applications such as distributed uninterruptible power systems or microgrids [2], [3].

The conventional droop control presents active and reactive power coupling and poor transient response [4]. In order to improve the active and reactive power decoupling performance, improved droop controllers are reported in [5] and [6]. Also, an enhanced droop controller featuring transient droop performance is proposed in [7]. The improved controllers are proposed based on the static droop characteristics combined with a derivative terms which can yield to a two degrees of freedom (2-DOF) tunable control in [8-10].

It is also well known that the performance of the conventional droop control is seriously affected by the inductance-to-resistance ( $X/R$ ) ratio of output and the line impedance. Microgrids, similarly as electrical distribution networks, present a low  $X/R$  ratio, so that voltage amplitude is generally used to control active power, while the angle dominates reactive power so that can be controlled by the

system frequency. This scheme is also named  $P$ - $V$  and  $Q$ - $f$  droop. In order to control active and reactive power according to the power line  $X/R$  ratio, resistive virtual impedance loops has been added to the droop control. In this sense, we can have a control framework that includes three control loops [11], [12]: (i) virtual resistance; (ii)  $P$ - $V$  droop; and (iii)  $Q$ - $f$  droop. However it is complex to design the virtual resistance and the  $P$ - $V$  droop coefficients since both affect voltage amplitude regulation with control loops that present different control bandwidths.

Further, an orthogonal linear rotational transformation matrix  $T$  can be employed to transform active and reactive power and to a new transformed active and reactive powers when both  $X$  and  $R$  need to be considered [13]. However this method requires precise line impedance value estimation, which is difficult to known. In order to reduce the influence of the  $R/X$  ratio on droop controller and improve the active and reactive power decoupling performance, a fast control loop named virtual impedance is added into the droop controller [14], [15].

However, all abovementioned improved approaches present the inherent drawback of needing to calculate instantaneous active and reactive powers, thus needing for low-pass filters to average values which bandwidth will impact the system transient response [16]. Even in the case of three-phase systems that the active and reactive power can be calculated by using the instantaneous power theory, a post-filter processing is necessary in order to eliminate the distorted power components [17]. Furthermore, in practical situations the load sharing performance of the conventional droop control is degraded when using short lines with small impedance, especially in low voltage networks. In this case, a very small deviation in voltage frequency and amplitude will result in large power oscillation and even instabilities [16].

With the aim to overcome the aforementioned problems, a control strategy by using a different view point is proposed in this paper. The approach is based on using a virtual resistance loop and to substitute the whole droop control by a phase locked loop (PLL). This way, the PLL adjust the phase of the inverter, and the system is controlled by a virtual resistance controlling current as in a dc electrical system, in a sharp

contrast as in ac systems, in which active and reactive power sharing is required. In comparison with the traditional virtual resistance plus  $P$ - $V$  and  $Q$ - $f$  droop control framework, the proposed controller endows a faster dynamic response to the paralleled system, allowing higher stability margins and easy to implement and to design. The proposed approach has been verified by using simulation and experimental results in laboratory prototypes.

## II. A REVIEW OF THE POWER FLOW ANALYSIS IN DROOP CONTROLLED MICROGRIDS

Fig. 1 shows the equivalent circuit of two inverters connected in parallel sharing a common load, which can be considered as a subset of the distributed power network operating in autonomous islanded mode. The system model consist of two voltage sources connected through a series equivalent impedance (  $Z_1 \angle \varphi_1$  and  $Z_2 \angle \varphi_2$  ), which encompasses the inverter output impedance (  $Z_{o1} \angle \varphi_{oZ1}$  and  $Z_{o2} \angle \varphi_{oZ2}$  ) and the line impedance (  $Z_{line1} \angle \varphi_{line1}$  and  $Z_{line2} \angle \varphi_{line2}$  ). The output voltage of each inverter is denoted by  $V_{o1} \angle \varphi_{o1}$  and  $V_{o2} \angle \varphi_{o2}$  and the voltage for point of common coupling by  $V_{bus} \angle \varphi_{bus}$ .




Fig. 1. Equivalent circuit of two inverters operating in autonomous mode.

In traditional power systems, the equivalent impedances between the paralleled inverters present high  $X/R$  ratio, that means  $\varphi_{line} \cong 90^\circ$ . Thus the output active and reactive powers (  $P_n$  and  $Q_n$  ) of inverter  $n$  ( $n=1, 2$ ) can be presented as follows

$$P_n = \frac{V_{on} V_{bus} \sin(\varphi_{on} - \varphi_{bus})}{Z_n} \quad (1)$$

$$Q_n = \frac{V_{on}^2 - V_n V_{bus} \cos(\varphi_{on} - \varphi_{bus})}{Z_n} \quad (2)$$

From equations (1) and (2), a set of partial differential equations can be derived as follows:

$$\frac{\partial P_n}{\partial \varphi_n} = \frac{V_{on} V_{bus} \cos(\varphi_{on} - \varphi_{bus})}{Z_n} \quad (3)$$

$$\frac{\partial P_n}{\partial U_n} = \frac{V_{bus} \sin(\varphi_{on} - \varphi_{bus})}{Z_n} \quad (4)$$

$$\frac{\partial Q_n}{\partial \varphi_n} = \frac{V_{on} V_{bus} \sin(\varphi_{on} - \varphi_{bus})}{Z_n} \quad (5)$$

$$\frac{\partial Q_n}{\partial U_n} = \frac{2V_{on} - V_{bus} \cos(\varphi_{on} - \varphi_{bus})}{Z_n} \quad (6)$$

By considering  $\varphi_{on} - \varphi_{bus} \approx 0$  and  $Z_n$  large enough, we can easily adjust active power  $P_n$  with the output voltage angle  $\varphi_{on}$  and reactive power  $Q_n$  with the output voltage amplitude  $V_{on}$ . Based on this power flow analysis, the droop control law can be expressed as:

$$\omega_n = \omega_n^* + k_{p\omega} (P_n^* - P_n) \quad (7)$$

$$V_n = V_n^* + k_{qV} (Q_n^* - Q_n) \quad (8)$$

where,  $\omega_n^*$  and  $V_n^*$  are the normal output frequency and voltage amplitude, respectively.

However, in a practical situation the load sharing performance of the conventional droop control is degraded when using short lines with small impedances, especially in low voltage networks. The reason of this is that since  $[\sin(\varphi_{on} - \varphi_{bus})]/Z_n \approx (\varphi_{on} - \varphi_{bus})/Z_n$  will not be neglect when  $\varphi_n - \varphi_{com} \neq 0$  or  $Z_n$  is too small. In this case, each equation from (3) to (6) cannot be well approximated to zero, so that the output power ( $P_n$  and  $Q_n$ ), output voltage amplitude ( $V_n$ ) and frequency ( $\omega_n$ ) are coupled, which will result in imprecise power control. Furthermore, conventional droop controlled systems may present instabilities since small voltage frequency or amplitude deviations may result in large power oscillations when  $Z_n$  is very small.

## III. CURRENT FLOW ANALYSIS – THE CHANGE OF PARADIGM

Fig. 1 can be further simplified to an equivalent circuit of a two-paralleled inverter system including output voltages (  $V_{o1}$  and  $V_{o2}$  ), output impedances (  $Z_{o1}$  and  $Z_{o2}$  ), virtual resistances (  $R_{vir1}$  and  $R_{vir2}$  ), and line impedances (  $Z_{line1}$  and  $Z_{line2}$  ) of each inverter as shown in Fig. 2.




Fig. 2. Equivalent circuit of a parallel inverter system with virtual resistances.

This way, each inverter can be modeled by a two-terminal Thévenin equivalent circuit as follows

$$V_{bus}(s) = G(s) \cdot V_{ref}(s) - [Z_o(s) + Z_{line}(s) + R_{vir}] \cdot I_o(s) \quad (9)$$





Fig. 3. Block diagram of the closed loop system including virtual impedance.


where  $V_{ref}(s)$  is the output voltage reference and  $G(s)$  is the voltage tracking gain,  $G(s) \cdot V_{ref}(s)$  presents the generate voltage of the inverter  $V_o$ .

The output impedance of inverter  $Z_o(s)$  is not only affected by the filter parameters but also influenced by the controller structure and parameters. The inner current and voltage loops will be responsible to make  $Z_o(s)$  as small as possible. In this paper, proportional-resonant (PR) controllers tuned at the line frequency are used to make  $Z_o(s)$  equals to zero at 50Hz. The block diagram of inner current and voltage loop with virtual impedance is shown in Fig. 3.

From Fig. 3, the closed loop output impedance  $Z'_o(s)$  which is modified by virtual impedance  $Z_{vir}(s)$  can be obtained as follows:



(a) Virtual resistance



(b) Virtual inductance

Fig. 4. Bode diagram of the closed-loop output impedance with virtual impedance.

$$Z'_o(s) = -\frac{u_o(s)}{i_o(s)} = \frac{Ls+r+Z_{vir}(s)K_{PWM}G_u(s)G_i(s)}{LCs^2+[r+K_{PWM}G_i(s)]Cs+K_{PWM}G_u(s)G_i(s)+1} \quad (10)$$

where  $Z_{vir}(s)$  is the virtual impedance,  $K_{PWM}$  is the gain of the pulse width modulation (PWM),  $G_u(s)$  is the voltage loop PR controller,  $G_i(s)$  is the Proportional controller of the current loop, and  $L$  and  $C$  are the  $LC$  output filter parameters.

The frequency response of the closed-loop output impedance  $Z'_o(s)$  for  $Z_{vir}(s) = R_{vir}$  and  $Z_{vir}(s) = jX_{vir}$  cases are both shown in Fig. 4. From this figure it can be seen that  $|Z'_o(s)|$  is highly dependent on the virtual impedance magnitude and angle.

In addition, since  $Z_{line}(s)$  is practically very small in low scale electrical systems such as microgrids,  $R_{vir}$  becomes the predominant component, so that (1) can be expressed in Laplace domain as

$$V_{bus}(s) = G(s) \cdot V_{ref}(s) - R_{vir} \cdot I_o(s) \quad (11)$$

which corresponds to a Thévenin equivalent circuit, as illustrated in Fig. 5.

In this paper, proportional-resonant (PR) controllers are used to make  $G(s)$  equals to 1 at 50Hz. Hence, the relationship of the common bus voltage ( $V_{bus}$ ), reference voltage ( $V_{ref}$ ), and output current ( $I_o$ ) vectors can be expressed in Euler form as follows:

$$\begin{aligned} V_{bus} &= V_{ref} - I_o \cdot R_{vir} \\ &= (V_{ref} \cos \varphi - I_o \cdot R_{vir} \cdot \cos \phi) + j(V_{ref} \sin \varphi - I_o \cdot R_{vir} \cdot \sin \phi) \end{aligned} \quad (12)$$

being  $\varphi$  the voltage reference angle and  $\phi$  the output current angle.

From Fig. 6 we can see that when varying  $R_{vir}$  will result in different output current vectors ( $I_o$ ). We can also express the vectors in a synchronous reference frame by decomposing direct and quadrature components as follows

$$V_{bus} = V_{refd} - R_{vir} \cdot I_{od} \quad (13a)$$

$$0 = V_{refq} - R_{vir} \cdot I_{oq} \quad (13b)$$




Fig. 5. Inverter closed-loop equivalent Thévenin circuit.



## V. EXPERIMENTAL RESULTS AND PERFORMANCE COMPARISON

In order to compare and evaluate the performance of the proposed control scheme with the conventional droop control, a scale-down laboratory prototype is built according to Fig.7. The time-domain model of the proposed control scheme is evaluated in Matlab/Simulink environment. The TMS320F2812 DSP based platform has been chosen for the real-time digital experimental tests. The system parameters are given in Table I and II.

TABLE I  
SYSTEM PARAMETERS OF PROPOSED CONTROLLER

Parameters	Values	Parameters	Values
$U_{dc}$	250 V	$C_f$	9.9 $\mu$ F
$k_{pi}$	0.603	$k_i$	18.47
$R_{load}$	20 $\Omega$	$f_c$	40 kHz
$L_f$	3 mH	$\omega_c$	30 rad/s
$k_p$	0.053	$R_{vir}$	3 $\Omega$
$f_s$	20 kHz	$L_{line}$	7/3.5/0 mH

TABLE III  
SYSTEM PARAMETERS OF CONVENTIONAL DROOP CONTROLLER

Parameters	Values	Parameters	Values
$U_{dc}$	250 V	$C_f$	9.9 $\mu$ F
$k_{pi}$	0.603	$k_i$	18.47
$k_{qV}$	0.001	$f_c$	40 kHz
$R_{load}$	20 $\Omega$	$P^*$	750 W
$L_f$	3 mH	$\omega_c$	30 rd/s
$k_p$	0.053	$k_{p\omega}$	$4 \times 10^{-3}$
$f_s$	20 kHz	$L_{line}$	7/3.5/0 mH
$R_{start}$	2 $\Omega$	$Q^*$	750 var

Fig. 9 shows the simulation results of the paralleled inverter system by using the proposed control scheme. We can see that the active and reactive powers can be precisely controlled according to the ratio of the virtual resistance (1:2). In order to verify the feasibility of the proposed controller, different operating conditions have been considered in the experimental tests.

### A. Experimental tests comparison for large line impedance ( $L_{line} = 7mH$ )

Fig. 10 shows the output voltages and currents transient response for both the conventional droop control and the proposed controller when sharing a pure resistive load. Firstly, inverter #2 works standalone and then inverter #1 is plugged to the point of common coupling (PCC) to share the load with inverter #2. In order to damp the initial transient current and achieve the hot-swappable performance, a 2  $\Omega$  virtual resistance  $R_{start}$  used by inverter #2, lasting for 2 s when employing conventional droop control. It can be observed that the proposed controller can provide higher speed, and better

damping and precision performance power control than those in conventional droop control.





Fig. 9. Simulation results of the paralleled inverters when sharing an RL load.




(X-axis: time (a) 50 ms/div, (b) 5 ms/div, Y-axis: U 50V/div, i 5A/div)  
Fig. 10. Compared experimental results of transient responses for parallel inverters.


Fig.11 shows the steady output voltage waveform of inverter #1, output currents of both inverters and the circulating current based for both conventional droop and proposed controller. From Fig. 11, it can be observed that the

conventional droop control strategy can achieve load-sharing capability between the parallel inverters, but the circulating current is still large. The peak value of circulating current is nearly 2 A, which represents almost half of the inverter rated output current. The reason leading to this phenomenon is the presence of high-frequency harmonics in the capacitor current. This current is used as feed-forward of the internal current loop to improve the dynamic response and its harmonics result in waveform quality deterioration and increase of the circulating current. However the current sharing performance is quite good when employing the proposed controller in comparison with the droop control. The maximum value of circulating current is just 0.4 A.

Fig.12 shows the cut-off responses when inverter#1 disconnects from the PCC for the case of using conventional droop controller and the proposed one. It can be observed that when the inverter #1 is disconnected from the PCC, the output current of inverter #2 increases immediately to supply the load.




(a) Conventional droop control.




(b) Proposed control method.

(X-axis: time 5 ms/div, Y-axis: U 50V/div, i 5A/div)

Fig. 11. Experimental results comparison of the steady state waveforms.



(a) Conventional droop control.




(b) Proposed control method.

(X-axis: time 50 ms/div, Y-axis: U 50V/div, i 5A/div)


Fig. 12. Experimental results comparison between transient responses.

### B. Experimental tests comparison for small line impedance ( $L_{line} = 3.5 \text{ mH}$ and $L_{line} = 0 \text{ mH}$ )

The paralleled inverter system becomes unstable when using droop control with same parameters when the line impedance is reduced to 3.5 mH. The large transient over current results in activating the protection system when both inverters were connected. In contrast, the proposed controller can maintain the load sharing capability with  $L_{line} = 3.5 \text{ mH}$  and even 0 mH, as shown in Fig. 13, while the droop control was not able to endow a stable operation in such conditions.



(a)  $L_{line} = 3.5 \text{ mH}$ .



(b)  $L_{line} = 0 \text{ mH}$ .


(X-axis: time 5 ms/div, Y-axis: U 50V/div, i 5A/div)

Fig. 13. Steady waveforms of the parallel inverters using the proposed controller under small line impedance.

### C. Experimental tests with asymmetrical line impedance ( $L_{line1} = 7 \text{ mH}$ , $L_{line2} = 3.5 \text{ mH}$ )

Fig. 14 shows the current-sharing performance under asymmetrical line impedance when using the proposed controller. It can be observed that the proposed controller can

enlarge system stability margin, while obtaining a good load-sharing capability even under asymmetrical line impedance as shown in Fig. 14, even when the droop controller was not able to provide system stability.



(X-axis: time 5 ms/div, Y-axis: U 50V/div, i 5A/div)

Fig. 14. Steady waveforms of the parallel inverters with the U-I droop controller under different Line impedance.

The performance comparisons between both controllers are summarized in Table I. The proposed controller is faster than droop method since it does not require P/Q calculations, which limit the bandwidth of the system. Further, the use of filters, especially finite impulse response (FIR) requires increase the computational burden. Note that the conventional droop control requires for additional virtual impedance if we want to improve the aforementioned problems. In addition, conventional droop control is more complex to design since we need to adjust two droop coefficients plus the virtual impedance value. So that two terms ( $R_v$  and  $Q-V$  droop gain value) has to be considered at the same time to respect both maximum voltage deviation and proper transient response. The proposed controller solves the trade-off by only using the parameter  $R_v$ . There is a tradeoff between the power sharing accuracy and the voltage amplitude.

## VI. CONCLUSION

This paper proposed a novel control strategy which based on a virtual impedance and phase locked loop, which substitutes the conventional two droop control loops, for a parallel three-phase inverters. The load sharing performance of this controller just depends on output impedance ratio instead of the output impedance value of the two inverter modules which makes it quiet suitable applied in low-voltage microgrids with small line impedance values. In comparison to the traditional droop controller, the proposed controller could obtain faster dynamic response, extended stability margin, and simple control parameters design.

TABLE III  
PERFORMANCE COMPARISON

Performances	P-V/Q-V droop	Proposed control
Transient response	Slow	Fast
Control design	Complex	Simple
Computational load	High	Low
Control parameters	$m, n, R_v$	$R_v$

## REFERENCES

- [1] Guerrero, J.M.; Chandorkar, M.; Lee, T.; Loh, P.C., "Advanced Control Architectures for Intelligent Microgrids—Part I: Decentralized and Hierarchical Control," *Industrial Electronics, IEEE Transactions on*, vol.60, no.4, pp.1254,1262, April 2013
- [2] Chandorkar, M.C.; Divan, D.M.; Adapa, R., "Control of parallel connected inverters in standalone AC supply systems," *Industry Applications, IEEE Transactions on*, vol.29, no.1, pp.136,143, Jan/Feb 1993
- [3] Lasseter, R.H., "MicroGrids," *Power Engineering Society Winter Meeting, 2002. IEEE*, vol.1, no., pp.305,308 vol.1, 2002
- [4] Cooper K., Dasgupta A, Kennedy K, et al, "New Grid Scheduling and Rescheduling Methods in the GrADS Project," *Proceedings of 18th International Parallel and Distributed Processing Symposium*, vol.18, pp. 2775–2782, 2004.
- [5] J. Guerrero, L. de Vicuna, J. Matas, M. Castilla, and J. Miret, "A wireless controller to enhance dynamic performance of parallel inverters in distributed generation system," *IEEE Trans. Power Electron.*, vol. 19, no. 5, pp. 1205–1213, Sep. 2004.
- [6] S. J. Chiang, C. Y. Yen, and K. T. Chang, "A multimodule parallelable series-connected PWM voltage regulator," *IEEE Trans. Ind. Electron.*, vol. 48, no. 3, pp. 506–516, Jun. 2001.
- [7] J. Guerrero, L. de Vicuna, J. Matas, M. Castilla, and J. Miret, "A wireless controller to enhance dynamic performance of parallel inverters in distributed generation system," *IEEE Trans. Power Electron.*, vol. 19, no. 5, pp. 1205–1213, Sep. 2004.
- [8] C. Sao and P. Lehn, "Autonomous load sharing of voltage source converters," *IEEE Trans. Power Del.*, vol. 20, no. 2, pp. 1009–1016, Apr. 2005.
- [9] Yasser Abdel-Rady Ibrahim Mohamed, Ehab F. El-Saadany. "Adaptive Decentralized Droop Controller to Preserve Power Sharing Stability of Paralleled Inverters in Distributed Generation Microgrids," *IEEE Transactions on Power Electronics*, vol. 23, no. 6, pp.2806-2816, Nov.2008
- [10] Yajuan Guan, Weiyang Wu, Xiaoqiang Guo, Herong Gu. "An Improved Droop Controller for Grid-Connected Voltage Source Inverter in Microgrid." *2nd International Symposium on Power Electronics for Distributed Generation Systems, PEDG 2010*, 2010: 823-828
- [11] Guerrero, J.M.; Matas, J.; Luis Garcia de Vicuna; Castilla, M.; Miret, J., "Decentralized Control for Parallel Operation of Distributed Generation Inverters Using Resistive Output Impedance," *Industrial Electronics, IEEE Transactions on*, vol.54, no.2, pp.994,1004, April 2007
- [12] Vandoom, T.L.; Meersman, B.; Degroote, L.; Renders, B.; Vandeveld, L., "A Control Strategy for Islanded Microgrids With DC-Link Voltage Control," *Power Delivery, IEEE Transactions on*, vol.26, no.2, pp.703,713, April 2011
- [13] Engler A, Soutanis N. "Droop control in LV-grids[C]"// *International Conference on Future Power Systems*, USA : IEEE, 2005 : 1-6.
- [14] J. Guerrero, L. de Vicuna, J. Matas, M. Castilla, and J. Miret, "A wireless controller to enhance dynamic performance of parallel inverters in distributed generation system," *IEEE Trans. Power Electron.*, vol. 19, no. 5, pp. 1205–1213, Sep. 2004.
- [15] S. J. Chiang, C. Y. Yen, and K. T. Chang, "A multimodule parallelable series-connected PWM voltage regulator," *IEEE Trans. Ind. Electron.*, vol. 48, no. 3, pp. 506–516, Jun. 2001.
- [16] Coelho, E.A.A.; Cortizo, P.C.; Garcia, P.F.D., "Small-signal stability for parallel-connected inverters in stand-alone AC supply systems," *Industry Applications, IEEE Transactions on*, vol.38, no.2, pp.533,542, Mar/Apr 2002
- [17] Vasquez, J.C.; Guerrero, J.M.; Savaghebi, M.; Eloy-Garcia, J.; Teodorescu, R., "Modeling, Analysis, and Design of Stationary-Reference-Frame Droop-Controlled Parallel Three-Phase Voltage Source Inverters," *Industrial Electronics, IEEE Transactions on*, vol.60, no.4, pp.1271,1280, April 2013